



Texas Commission on Environmental Quality

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS: Issue Boil Water Notice

Public Water System (PWS) name: Pennington WSC

PWS ID: 2280009 Date of Incident/Violation: 8-2-22

Area Affected: Entire PWS Other Area: FM 4555 + back side of Lake Creek Cem Rd

Reason(s) issued: (indicate "X" all applicable circumstances; 30 TAC 290.46 (q))

- Low distribution pressures (<20psi)
- Water outage
- E. coli or fecal positive microbiological sample(s)
- Failure to maintain adequate chlorine residuals
- Elevated finished water turbidities (Surface Water Treatment Rule)
- Line Break
- Other: _____

30 TAC 290.46(q)(1) requires that your PWS make an adequate, good-faith effort to reach all consumers served by the system by appropriate methods (check all below that apply):

COMMUNITY WATER SYSTEM (perform one or more of the following):

- Furnish a copy of the Notice to radio and television stations serving the PWS service area
- Publish Notice in a local newspaper serving the PWS service area
- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

NONCOMMUNITY WATER SYSTEM (perform one or more of the following):

- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

NOTE: 30 TAC 290.46(q)(6)(F) requires the PWS to provide documentation to the Executive Director within 10 days.

Date of Delivery to Customers: 8-2-22 Phone: (936)638-4411

Certified by: (print name): Karen M Avery Title: office manager

Signature: [Signature] Date: 8-2-22

E-mail (PWSBWN@tceq.texas.gov) or mail a copy of this completed form, AND copies of the Boil Water Notice given to your customers to: TCEQ – Water Supply Division MC – 155, Attn: Public Notice. P. O. Box 13087 Austin, TX 78711-3087

Boil Water Notice

On August 2, 2022, the Texas Commission on Environmental Quality (TCEQ) required the Pennington WSC, 22810009, to issue a Boil Water Notice (BWN) to inform their customers on and off of the intersection of CR 4555 and the backside of Lake Creek Cemetery Rd to boil their water prior to consumption. Children, Seniors, and persons with weakened immune systems are particularly vulnerable to harmful bacteria and all customers should follow these directions.

To ensure destruction of all harmful bacteria and other microbes, water for drinking, cooking, and ice making should be brought to a rolling boil and then boiled for two minutes.

In lieu of boiling, individuals may purchase bottled water or obtain water from some other suitable source for drinking water or human consumption purposes.

When it is no longer necessary to boil the water the public water system officials will notify customers that the water is safe for drinking water or human consumption purposes.

Once the boil water is no longer in effect, the public water system will issue a notice to customers that rescinds the boil water notice in a manner similar to this notice.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in public places or distributing them by hand or mail

If you have questions regarding this matter you may contact,
Tod English at (936)638-4411

If a customer wishes to reach TCEQ, they may call 512-239-4691.

Boil Water Rescind Notice

On August 2, 2022, the Texas Commission on Environmental Quality (TCEQ) required the Pennington WSC, 2280009 to issue a Boil Water Notice (BWN) to inform their customers on and off of CR 4555 and the backside of Lake Creek Cemetery Rd that due to the presence of contaminants or an interruption in service, water from our system must be boiled prior to consumption.

Children, Seniors, and persons with weakened immune systems are particularly vulnerable to harmful bacteria and all customers should follow these directions.

Our system has taken the necessary corrective actions to restore adequate pressure, disinfectant levels, and/or bacteriological quality and has provided TCEQ with testing results that indicate that the water no longer requires boiling as of 08/08/2022.

If you have questions, contact Tod English at (936)638-4411

If a customer wishes to reach TCEQ, they may call 512-239-4691.

TCEQ Microbial Reporting Form


TCEQ Form 10525
08/2017

Water System Identification & Sample Collection Information (Please type or use block print)

Public Water System ID: TX 2 2 8 0 0 0 9
(Must be 7 digits; include all zeros)

Public Water System Name: Pennington Water Supply, Inc.

ANRA Laboratory
2901 N. John Redditt Dr.
Lufkin, TX 75904
Phone: 936-632-7795
Fax: 936-632-2564



ANGELINA & NECHES RIVER AUTHORITY
Environmental Laboratory

TCEQ Laboratory
ID: TX48101

Test results must meet all accreditation/certification requirements unless stated otherwise.
SHADED AREA FOR LABORATORY USE ONLY

County: Trinity

Name: Pennington Water Supply, Inc.

Address: P O Box 15

City: Pennington

State: TX

Zip Code: 75856

Email: dwallaa@aol.com; penningtonwatersupply@yahoo.com

Phone #: 936-655-2271

Other Contact: 936-544-6739

Sample on Ice? Yes No

Thermometer ID: THERM-9

Correction Factor: -0.3

Observed Temp: 20.9 °C

Corrected Temp: 20.6 °C

Receipt #:

Relinquished By (Sampler Signature): *[Signature]*

Received By (Customer Signature): *[Signature]*

Relinquished By (Courier Signature):

Received By (ANRA Lab Signature): *[Signature]*

Tested By: *[Signature]*

Incubation In Date: 8/14/2022

Incubation Out Date: 8/15/2022

Incubation In Time: 16:24

Incubation Out Time: 13:14

Report to Client By: *[Signature]*

Date: 8/15/2022

Operator License #: WS0003223

Owner Operator Other:

Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37.10) By signing this form, the sampler acknowledges that samples were collected according to the systems established sample collection procedures, and that all information is accurate.

Use Specific Address / Location Identified in Sample Siting Plan

Raw Wells - Use Source ID for Well Sampled (Example: G1234567A)

Sample Identification / Location	Sample Type	Check One	Date Collected			Time	Please circle AM or PM	Replacement	Sample ID & Date of Originating Sample (All Repeat, Replacement, & Triggered Raw Samples)	Chlorine Residual Circle "r" for Free or "T" for Total, mg/L	Lab Results				Work Order #: 29069	Laboratory Sample ID Numbers
			Month	Day	Year						Test Method: SM 9223B	Chlorine Check	Total Coliform	E. coli		
Well III CLASS #5		<input checked="" type="checkbox"/> Routine (Distribution)	8	1	22	8:15	AM		98.5		X	X	X		558429	
		<input type="checkbox"/> Repeat														
		<input type="checkbox"/> Raw Well														
		<input type="checkbox"/> Special*														
		<input type="checkbox"/> Construction*														

Form Instructions: www.tceq.texas.gov/shinkingwater/newseid-total-coliform-rule * Special and Construction samples are NOT FOR COMPLIANCE. Rejection Code: BR - Broken in Transit, C - Chlorine Present, EH - Exceeds Holding Time, EV - Excessive Volume, LA - Lab Accident, NC - No Chlorine Residual, ST - Turbidity Present, VO - Volume Insufficient

*** FAX TX REPORT ***

TRANSMISSION OK

JOB NO.	0451
DESTINATION ADDRESS	15122393666
SUBADDRESS	
DESTINATION ID	
ST. TIME	08/08 11:42
TX/RX TIME	02' 25
PGS.	5
RESULT	OK



PENNINGTON WATER SUPPLY CORP.
P.O. BOX 15
PENNINGTON, TEXAS 75856
(936) 638-4411

.....

TOTAL PAGES, INCLUDING COVER

5

SEND TO : T.C.E.Q. Attn: Tom Heitman
Attn: Beaumont Water Dept

FAX NUMBER: (512) 239-3666
(409) 899-8778

COMMENTS, _____ Boil Water Notice Results _____
 _____ Certificate of Delivery _____
 _____ Notice _____
 _____ Rescind _____

Kennard CR 4555 8/2/22

REPLY A.S.A.P

PLEASE COMMENT

PLEASE REVIEW

*** FAX ERROR TX REPORT ***

TX FUNCTION WAS NOT COMPLETED

JOB NO.	0452
DESTINATION ADDRESS	14098998778
SUBADDRESS	
DESTINATION ID	
ST. TIME	08/08 11:51
TX/RX TIME	00' 00
PGS.	0
RESULT	NG
	0 #018 BUSY/NO SIGNAL



PENNINGTON WATER SUPPLY CORP.
P.O. BOX 15
PENNINGTON, TEXAS 75856
(936) 638-4411

.....

TOTAL PAGES, INCLUDING COVER

5

SEND TO : T.C.E.Q. Attn: Tom Heitman
Attn: Beaumont Water Dept

FAX NUMBER: (512) 239-3666
(409) 899-8778

COMMENTS, Boil Water Notice Results
Certificate of Delivery
Notice
Rescind

Kennard CR 4555 8/2/22

REPLY A.S.A.P

PLEASE COMMENT

PLEASE REVIEW



PENNINGTON WATER SUPPLY CORP.
 P.O. BOX 15
 PENNINGTON, TEXAS 75856
 (936) 638-4411

.....

TOTAL PAGES, INCLUDING COVER

5

SEND TO : T.C.E.Q. Attn: Tom Heitman
Attn: Beaumont Water Dept

FAX NUMBER: (512)239-3666
(409)899-8778

*Again -
 409 899-8778
 packed up
 I have not
 received notice
 of a #
 change*

COMMENTS, Boil Water Notice Results
Certificate of Delivery
Notice
Rescind

Kennard CR 4555 8/2/22

REPLY A.S.A.P

PLEASE COMMENT

PLEASE REVIEW